



**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION IX**

**Underground Storage Tanks Program Office
75 Hawthorne Street (WST-8)
San Francisco, CA 94105**

August 13, 2008

**REFER TO WST-8 AND SITE # NAV-020
Certified Mail: 7005 2570 0001 6436 6761**

Dr. Emmett Brown, Superintendent
Tuba City Unified School District #15
P.O. Box 67
Tuba City, AZ 86045

Subject: Tuba City Unified School District UST Site (NAV-020)

Dear Dr. Brown:


This correspondence refers to the documentation related to the cleanup activities of soil and groundwater contamination, conducted at the schools bus barn maintenance facility, where three underground storage tanks (USTs) were removed in 1990.

Our review of the closure documents and analytical results for soil samples collected at this site indicate no hydrocarbon concentrations above appropriate EPA, Region IX or Navajo Nation EPA (NNEPA) soil screening levels.

This site does not appear to pose a current threat to human health and the environment. Therefore, EPA and NNEPA are not requiring further action at this time.

Please call Walt Guggenheimer of my staff at (415) 972-3377 or Henry Haven of the NNEPA at 928-871-7997 if you have questions or need more information.

Sincerely,


Steven C. Linder, P.E., Manager
Underground Storage Tanks Program Office

**Cc: Henry Haven, Navajo Nation EPA
Alan Downer, Navajo Nation HPD**

REFER TO WST-8 AND SITE # NAV-020
Certified Mail: 7005 2570 0001 6436 6761

Dr. Emmett Brown, Superintendent
Tuba City Unified School District #15
P.O. Box 67
Tuba City, AZ 86045

Subject: **Tuba City Unified School District UST Site (NAV-020)**

Dear Dr. Brown:

This correspondence refers to the documentation related to the cleanup activities of soil and groundwater contamination conducted at the schools bus barn maintenance facility where three underground storage tanks (USTs) were removed in 1990.

Our review of the closure documents and analytical results for soil samples collected at this site indicate no hydrocarbon concentrations above appropriate EPA, Region IX or Navajo Nation EPA (NNEPA) soil screening levels.

This site does not appear to pose a current threat to human health and the environment. Therefore, EPA and NNEPA are not requiring further action at this time.

Please call Walt Guggenheimer of my staff at (415) 972-3377 or Henry Haven of the NNEPA at 928-871-7997 if you have questions or need more information.

Sincerely,

Steven C. Linder, P.E., Manager
Underground Storage Tanks Program Office

Cc: Henry Haven, Navajo Nation EPA
Alan Downer, Navajo Nation HPD

SYMBOL	WST-8	WST-8	WST-1			
SURNAME	GUGGENHEIMER	Linder	Downer			
DATE	03/12/08	4/12/08	8/13/08			

U.S. EPA CONCURRENCES

OFFICIAL FILE COPY



**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION IX
Underground Storage Tanks Program Office
75 Hawthorne Street (WST-8)
San Francisco, CA 94105**

August 13, 2008

**REFER TO WST-8 AND SITE # NAV-020
Certified Mail: 7005 2570 0001 6436 6761**

Dr. Emmett Brown, Superintendent
Tuba City Unified School District #15
P.O. Box 67
Tuba City, AZ 86045

Subject: Tuba City Unified School District UST Site (NAV-020)

Dear Dr. Brown:


This correspondence refers to the documentation related to the cleanup activities of soil and groundwater contamination, conducted at the schools bus barn maintenance facility, where three underground storage tanks (USTs) were removed in 1990.

Our review of the closure documents and analytical results for soil samples collected at this site indicate no hydrocarbon concentrations above appropriate EPA, Region IX or Navajo Nation EPA (NNEPA) soil screening levels.

This site does not appear to pose a current threat to human health and the environment. Therefore, EPA and NNEPA are not requiring further action at this time.

Please call Walt Guggenheimer of my staff at (415) 972-3377 or Henry Haven of the NNEPA at 928-871-7997 if you have questions or need more information.

Sincerely,


Steven C. Linder, P.E., Manager
Underground Storage Tanks Program Office

**Cc: Henry Haven, Navajo Nation EPA
Alan Downer, Navajo Nation HPD**



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION IX
Underground Storage Tanks Program Office
75 Hawthorne Street (WST-8)
San Francisco, CA 94105

File
copy

September 19, 2005

REFER TO WST-8
AND SITE # NAV-020
Certified Mail: 7001 0320 0002 4540 2439

Mr. David Reese, Environmental Specialist
Western Technologies, Inc.
2400 East Huntington Drive
Flagstaff, AZ 86004

Subject: Tuba City Unified School District Bus Barn (NAV-020)

Dear Mr. Reese:

This correspondence refers to the telephone discussion between you and Walt Guggenheimer of my staff regarding the proposed modifications of the groundwater monitoring program at the Tuba City Unified School District's bus barn.

EPA supports the proposed quarterly sampling modifications indicated in your letter, dated September 7, 2005, which recommended sampling only MW-1, MW-5, MW-6, MW-9, MW-11 and MW-12, and the installation of two new monitoring wells (southwest and southeast of MW-11) to investigate the extent of the contaminant plume.

The next round of groundwater sampling is scheduled for this month. Please submit the quarterly groundwater monitoring report for this sampling event within 30 days of your receipt of the analytical data. Please call Walt Guggenheimer at 415-972-3377 if you have questions or need more information.

Sincerely,

Steven C. Linder, P.E., Manager
Underground Storage Tanks Program Office

Enclosure

cc: Henry Haven, Navajo Nation EPA
Ron Begay, Tuba City Unified School District #15
Julie Leid, Arizona Engineering Co.
David Prinzhom, Arizona Engineering Co.