

4/97

NFA for  
3 USTs  
installed  
in 1981.

IN REPLY REFER TO WST-8  
AND SITE # NAV-271-043  
Certified Mail Z 745 799 639

Mr. Mike Davis  
Cameron Trading Post  
P. O. Box 339  
Cameron, AZ 86020

Dear Mr. Davis:

Cochise Contractors, Inc. has submitted the Underground Storage Tank (UST) Closure Report for the three USTs removed at the Cameron Trading Post in Cameron, AZ, on land of the Navajo Nation. The report was prepared by Blaes Environmental Management, Inc. of Scottsdale, AZ under contract with Cochise.

Was incorrectly  
in the "Correspondence  
to EPA" section of  
this folder.  
C. Brokey  
7/3/07

The information submitted has assisted EPA in assessing the status of this site, where three 10,000-gallon Underground Storage Tanks (USTs) were removed on November 5, 1996. **This site does not appear to currently pose a threat to human health and the environment. EPA DOES NOT REQUIRE FURTHER ACTION AT THIS TIME WITH RESPECT TO THESE USTs AND ASSOCIATED PIPING.**

If other USTs are installed at the site, Tank Notification Form # 7530- 1 must be completed and sent to this office. We have no record of the new USTs which remain in service at this site. Please complete the attached form and return to this office no later than 30 days after receipt of this letter.

All tanks must be equipped with serviceable leak detection devices to be in compliance with federal regulations. In addition, all tanks must be upgraded to conform in all respects to regulations detailed in 40 CFR §280.20 and § 280.21 not later than December 22, 1998 or tanks must be closed in accordance with 40 CFR § 280.71